

**ADDENDUM TO FACT SHEET
MODIFICATION OF WASTE DISCHARGE PERMIT FOR
BIRCH BAY WATER AND SEWER DISTRICT
(NPDES Permit No. WA-002955-6)**

March 20, 2006

This is an addendum to the fact sheet accompanying the National Pollutant Discharge Elimination System (NPDES) Waste Discharge Permit No. WA-002955-6, which was issued to Birch Bay Water and Sewer District on July 1, 2002. The facility sent a request to have their permit modified on September 30, 2005. The following revision is made as a major modification.

PROPOSED MODIFICATION FOR THE PERMIT

Page 19 of the permit – a definition of the acute critical effluent concentration (ACEC) was inaccurate when it described it as 25% of the allowable effluent at the edge of the acute zone. The ACEC should be defined as 2.5% of the effluent allowable at the edge of the acute mixing zone. The permit also lacked a definition for the chronic critical effluent concentration (CCEC). A definition has been provided and the CCEC equals .775% effluent.

PUBLIC NOTICES

The proposed changes made in this permit are considered to constitute a major modification under 40 CFR 122.63. Thus, the changes made in the above-referenced permit are required to be published for a 30-day public review and comment period.